

PROJECT NAME:			Construction of Ankara Central (İvedik) Water Treatment Plant Capacity Increase (4th Unit) Project		
REPLIES TO QUERIES AND CLARIFICATIONS NO. 6					
No.	Bidding Document	Bidding Document Reference Clause	Clarification Requested by the Prospective Bidders	Reply of the Employer	Amendment in the Initial Selection Document is required YES or NO (If "YES" Provide Amendment Number)
1	Desing Dossiers	-	Confirm the labelling values of the sludge feed pumps (P-1000/1-2-3-S) in the sludge dewatering building.	Labelling values of sludge feed pumps in the project file named '11-) IVD (4) -IAT - MEK - ESB - 01-.....-07-S' Flow Rate = 50 m³/h Head = 20 mSS Engine Power = 15 kW The specified pump head shows the minimum value. However, detailed information about the pump specifications can be found in the 'Process Report' file under the sludge dewatering heading.	No
2	Request for Bids Works	Section III - Evaluation and Qualification Criteria (Without Prequalification)	In 'Section III - Evaluation and Qualification Criteria, 1.5 Equipment', under the category of mechanical hand compactor equipment, the types of double drum roller, plate and rammer are specified. Can all mechanical compactors be supplied as a single type such as double drum roller?	Yes, it must be of the type specified in the category of mechanical hand compactor equipment in 'Section III - Evaluation and Qualification Criteria, 1.5 Equipment'	No
3	Request for Bids Works	Particular Conditions	'Part 3 - Conditions of Contract and Contract Form, Section IX - Special Conditions, Part A - Contract Data, sub-clauses 19.2.3(a), 19.2.4 and 19.2.5 - Amount of insurance required for liability for breach of professional duty: EUR 60,000,000 - The amount of insurance required for personal injury and property damage: EUR 10,000,000.00 per occurrence with an unlimited number of occurrences - The amount of insurance required for injuries to employees: a) in case of death: 300.000,00 EUR, b) in case of injury: EUR 150.000,00 (one hundred and fifty thousand Euro) Can you please confirm that these amounts are intended?	Yes, it is confirmed	No
4	Request for Bids Works	Particular Conditions	'In Section 3 - Conditions of Contract and Contract Form, Part IX - Special Conditions, Section A - Contract Data, sub-clause 19.1, you have stated that there will be no permitted exemption limit. Can you please confirm that this is intended?	Yes, it is confirmed	No
5	Request for Bids Works	Section IV - Bidding Forms Form of Bid Security - Demand Guarantee	Could you please confirm whether the "Demand Guarantee" document will be accepted if it is submitted in "Turkish-English" and whether the Turkish document will be accepted as the basis and the English document will be accepted for informational purposes?	According to ITB 10.1 "The language of the Bid is: English. All correspondence exchange shall be in English. Language for translation of supporting documents and printed literature is English." article in the "Request for Bids – Works" document, if the "Form of Bid Security - Demand Guarantee" document is submitted bilingually, the valid language shall be English.	No